



CERTIFICATE OF APPROVAL

ISSUED PURSUANT TO SECTION 21C OF THE ELECTRICITY ACT 1945

ISSUED TO:

Feller GmbH

CLASS OF ARTICLE:

Supply Flexible Cord

DESCRIPTION OF ARTICLE:

Supply Flexible Cord
(3 Core, 1.5 mm sq, PVC insulated and sheathed ordinary
duty circular flexible cord with untinned copper conductors)
Trade Name: 'Feller'
300/500V

TYPE REFERENCE CODE: Type No. OD3CCFC

APPROVAL MARK:

Each electrical article of the abovementioned type shall be marked
with N14778 or N1095

DATE OF APPROVAL: 15 March 1996

*This approval expires 5 YEARS from the date of approval unless
renewed or extended*

R S W Neil
DIRECTOR-GENERAL



Ref: A14778/1

ADDENDUM TO CERTIFICATE OF APPROVAL No 14778

Particulars of Modification(s)

Original Type No. OD3CCFC modified by the alternative use of:-

- (a) 3 x 1.00 mm sq untinned copper conductors; and
- (b) 3 x 0.75 mm sq untinned copper conductors.

Type No. OD2CCFC being similar to original Type No. OD3CCFC except:-

- (a) Two-core in lieu of three core; and
- (b) The alternative use of 2 x 1.5 mm sq, 2 x 1.00 mm sq or 2 x 0.75 mm sq untinned copper conductors.

Type No. OD2CFFC being similar to original Type No. OD3CCFC except a two-core, 0.75 mm sq, PVC insulated and sheathed, ordinary duty flat flexible cord.

Type No. LD3CCFC being similar to original Type No. OD3CCFC except a three-core, 0.75 mm sq, PVC insulated and sheathed, light duty circular flexible cord.


Type No. LD2CCFC being similar to modification Type No. LD3CCFC except two-core in lieu of three-core.


Type No. LD2CFFC being similar to modification Type No. OD2CFFC except light duty in lieu of ordinary duty.

The use of the following alternative Type Nos:-

- H05VV-F3G as an alternative to OD3CCFC.
- H05VV-F2 as an alternative to OD2CCFC.
- H05VVH2-F as an alternative to OD2CFFC.
- H03VV-F3G as an alternative to LD3CCFC.
- H03VV-F2 as an alternative to LD2CCFC.
- H03VVH2-F as an alternative to LD2CFFC.

Approved : 15 March 1996


R S W Neil
DIRECTOR-GENERAL



Ref: N14778/2

DEPARTMENT OF **FAIR TRADING**
NSW Consumer Protection Agency

RENEWAL OF CERTIFICATE OF APPROVAL No 14778

PARTICULARS OF RENEWAL

The approval of Supply Flexible Cord Cat No. OD3CCFC and approved modifications has been renewed for a period of FIVE years.

Date of Renewal: 20 December 2000

The Approval expires on 20 December 2005 unless it is renewed, extended, suspended or cancelled.


for DIRECTOR-GENERAL

Ref: 14778/3

RENEWAL OF CERTIFICATE OF APPROVAL 14778

PARTICULARS OF RENEWAL

The approval of Supply Flexible Cord Type OD3CCFC and all approved modifications has been renewed for a period of FIVE years.

Date of Renewal: 21 November 2005

The Approval expires on 20 December 2010 unless it is renewed, extended, suspended or cancelled.



for Commissioner for Fair Trading

Ref: 14778/4

ADDENDUM TO CERTIFICATE OF APPROVAL 14778

Particulars of Modification(s)

Type No. H05VV-F 3G2.5mm² being similar to original Type No. OC3CCFC except having a conductor size of 2.5mm² in lieu of 1.5mm².

Approved: 25 July 2007



for Commissioner for Fair Trading



Fair
Trading

Ref: NSW14778/5

RENEWAL OF CERTIFICATE OF APPROVAL NSW14778

PARTICULARS OF RENEWAL

The approval of Supply Flexible Cord Type OD3CCFC and all approved modifications has been renewed for a period of FIVE years.

The Approval expires on 20/12/2015 unless it is renewed, extended, suspended or cancelled.

A handwritten signature in black ink, appearing to be "R. L. J.", written over a horizontal line.

for Deputy Commissioner, Fair Trading Operations



**Fair
Trading**

Ref: NSW14778/6

RENEWAL OF CERTIFICATE OF APPROVAL: NSW14778

Particulars of Renewal

The approval of Supply Flexible Cord Cat No. OD3CCFC and all approved modifications has been renewed for a period of FIVE years.

The Approval expires on 20/12/2020 unless it is renewed, extended, suspended or cancelled.


For Commissioner for Fair Trading



**Fair
Trading**

Ref: NSW14778/7

RENEWAL OF CERTIFICATE OF APPROVAL: NSW14778

Particulars of Renewal

The approval of Supply Flexible Cord Cat No. OD3CCFC and all approved modifications has been renewed for a period of FIVE years.

The Approval expires on 20/12/2025 unless it is renewed, extended, suspended or cancelled.

Approved pursuant to Clause 11 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018

15 January 2021

For Secretary, Department of Customer Service



DEPARTMENT OF **FAIR TRADING**
NSW Consumer Protection Agency

Certificate Number: 17268

CERTIFICATE OF APPROVAL

ISSUED PURSUANT TO SECTION 21C OF THE ELECTRICITY SAFETY ACT 1945

ISSUED TO:

Feller GmbH

CLASS OF ARTICLE:

Supply Flexible Cord

DESCRIPTION OF ARTICLE:

Supply Flexible Cord
(Three-core, 1.5 mm², 105 Deg C, PVC insulated and sheathed, ordinary duty
circular flexible cord with untinned copper conductors)
300/500V

EXAMINED FOR COMPLIANCE WITH: AS/NZS 3191 : 1996 A1-2

TYPE REFERENCE CODE: Cat No. H05V2V2-F 3G1.5


APPROVAL MARK:

Each electrical article of the abovementioned type shall be marked with Approval Number
N17268

DATE OF APPROVAL: 20 December 2000

This approval expires 20 December 2005 unless suspended, cancelled, renewed or extended.


for DIRECTOR-GENERAL



Ref: N17268/1

DEPARTMENT OF **FAIR TRADING**
NSW Consumer Protection Agency

ADDENDUM TO CERTIFICATE OF APPROVAL No 17268

Particulars of Modification(s)

- (a) Cat No. H05V2V2-F 3G1.0 being similar to original Cat No. H05V2V2-F 3G1.5 except having 1.00mm² in lieu of 1.5 mm² conductors.
- (b) Cat No. H05V2V2-F 3G0.75 being similar to original Cat No. H05V2V2-F 3G1.5 except having 0.75 mm² in lieu of 1.5 mm² conductors.
- (c) Cat No. H05V2V2-F 2X1.00 being similar to modification Cat No. H05V2V2-F 3G1.00 except two-core in lieu of three-core.
- (d) Cat No. H05V2V2-F 2X0.75 being similar to modification Cat No. H05V2V2-F 2X1.00 except having 0.75mm² in lieu of 1.00 mm² conductors.

Approved: 20 December 2000

for DIRECTOR-GENERAL

Ref: 17268/2

RENEWAL OF CERTIFICATE OF APPROVAL 17268

PARTICULARS OF RENEWAL

The approval of Supply Flexible Cord Cat. No. H05V2V2-F 3G1.5 and approved modifications has been renewed for a period of FIVE years.

Date of Renewal: 14 October 2005

The Approval expires on 20 December 2010 unless it is renewed, extended, suspended or cancelled.



for Commissioner for Fair Trading



Fair
Trading

Ref: NSW17268/3

RENEWAL OF CERTIFICATE OF APPROVAL NSW17268

PARTICULARS OF RENEWAL

The approval of Supply Flexible Cord Cat No. H05V2V2-F 3G1.5 and all approved modifications has been renewed for a period of FIVE years.
The Approval expires on 20/12/2015 unless it is renewed, extended, suspended or cancelled.

A handwritten signature in black ink, appearing to be "C. J. [unclear]".

for Deputy Commissioner, Fair Trading Operations



Fair
Trading


Ref: NSW17268/4

RENEWAL OF CERTIFICATE OF APPROVAL: NSW17268

Particulars of Renewal

The approval of Supply Flexible Cord Cat No. H05V2V2-F 3G1.5 and all approved modifications has been renewed for a period of FIVE years.

The Approval expires on 20/12/2020 unless it is renewed, extended, suspended or cancelled.


For Commissioner for Fair Trading

Energy & Utilities Unit, NSW Fair Trading,
PO Box 972, Parramatta NSW 2124
02 9895 0722

Email: energyapprovals@services.nsw.gov.au
Website: www.fairtrading.nsw.gov.au



Fair
Trading

Ref: NSW17268/5

RENEWAL OF CERTIFICATE OF APPROVAL: NSW17268

Particulars of Renewal

The approval of Supply Flexible Cord Cat No. H05V2V2-F 3G1.5 and all approved modifications has been renewed for a period of FIVE years.

The Approval expires on 20/12/2025 unless it is renewed, extended, suspended or cancelled.

Approved pursuant to Clause 11 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018

15 January 2021

For Secretary, Department of Customer Service



No. 10816

ELECTRICITY DEVELOPMENT ACT, 1945

CERTIFICATE OF APPROVAL

THIS IS TO CERTIFY that the [REDACTED] has, for the purposes of part IVC of the Electricity Development Act, 1945, approved the type of electrical article specified hereunder.

This certificate is issued to: Feller GmbH

of A-2525 Guenselsdorf, Austria

Each electrical article of that type shall be marked by the letter "N" followed by the approval number as indicated :-

Approval Marking: N/10816

Class of Article: Flexible Cord

Description of Article: (3 core 1.0mm² (30/0.2mm) tinned copper conductors elastomer insulated (R-60) elastomer sheathed (R-60) circular ordinary duty) 300/500V,

Identification Number: Cat. No. H05RR-F 3G1

Issued this Thirtieth day of July, 1987.

E. Watson
N C Watson
Secretary,

RENEWAL OF CERTIFICATE OF APPROVAL: NSW10816

Particulars of Renewal

The approval of Supply Flexible Cord Model No. H05RR-F 3G1 has been renewed for a period of FIVE years.

The Approval expires on 22/09/2027 unless it is renewed, extended, suspended or cancelled.

Approved pursuant to Clause 11 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018



19 September 2022

For Secretary, Department of Customer Service