

HOSPITAL GRADE PLUG,
CAT. NO. HG

FIG. 1 (M96-11890)

1. Blades - (Not as shown) Recognized Component (AXNU2), manufactured by Taller GmbH, Cat. Nos. E01.099 (21.V01.099), E01.199 suitable for use with the conductors types and size, insulation class and curling method as specified in the installation instructions provided with the blade. Blade is secured to conductors using the tools, method and recommended crimp height as specified in the blade installation instruction sheet for the blade employed.
2. Body - Molded of one of the plastic materials tabulated in Construction Details portion of report. Min 3/32 in (2.4 mm) thickness of molding material covers live parts, overall length 2-1/4 in (57.1 mm) including cord entry.
3. Face - Overall dimensions 1-1/4 in (31.7 mm) dia.
4. Cord Entry - Overall dimensions 7/16 in (11.1 mm) long, 19/32 in (15.1 mm) dia.

- * 5. **Flexible Cord - Listed Flexible (ZJCZ/7). See the following table for details.**

Cord Size (AWG)	Cord Type	USL	CNL or CSA Certified
18	SJT, SJTO, SJTW, SJTOW, SJTOOW, SJTOO	YES	YES
16	SJT, SJTO, SJTW, SJTOW, SJTOOW, SJTOO	YES	YES
14	SJT, SJTO, SJTW, SJTOW, SJTOOW, SJTOO	YES	YES

6. Marking - (Not shown) Listee's name or trademark molded on body.